

# Certificate



for European Product Safety

Reference No. 901349

## Wall mounted fan

Type designation Fresh Intellivent

Certificate holder **FRESH AB**  
**Box 7**  
**360 32 Gemla**  
**SWEDEN**

The product complies with the standard(s) EN 60335-1:2002+A11+A1+A12+A2+A13  
EN 60335-2-80:2003+A1  
EN 62233:2008

Date of expiry 7 July 2014

EU Directive information The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed

  
Shan Sohrabiyani

Date 7 July 2009

Page 1 of 2



# Appendix

Reference No. 901349

### Technical data

Type designation	Fresh Intellivent
Rated voltage (V)	100-240
Rated power (W)	5
Frequency (Hz)	50-60
Class	II
IP-Class	44


Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the products according to the Low Voltage Directive 2006/95/EC.

Manufacturing site(s)      Fresh AB  
    Granholms Bruk

   360 32 Gemla  
    SWEDEN

Certification Body      Intertek Semko AB, Product Certification      Place      Kista - Stockholm

Signed        
    Shan Sohrabiyani      Date      7 July 2009

*This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.*

42h